

- Equipment / Functions.....: EL. POWER:
- Cable size Main power:
 - 1- P – 001 1 x 400 mm²
 - P – 002 1 x 400 mm²
 - P – 003 1 x 400 mm²
 - P – 004 1 x 240 mm²

 - Rec. electrical protection: 2500A
 - Rec. aggregate: Min 1500 KVA

 - Purge air control cabinet : The air should have instrument air quality and should not under any circumstances have more than 15 degrees Celsius.
 - Strainer Element: MODENTIC SS304 (37-400 micron) DN150 6"
 - Flowmeter, Light, Pressure Transmitter, Y-strainer, Pressure Cabinets

 - Sound Pressure Level (SPL) (1 m free field) 98