



Equipment / Functions.....: EL. POWER:

Cable size Main power:

- 1- P – 001 1 x 400 mm<sup>2</sup>
- P – 002 1 x 400 mm<sup>2</sup>
- P – 003 1 x 400 mm<sup>2</sup>
- P – 004 1 x 240 mm<sup>2</sup>

- Rec. electrical protection: 2500A
- Rec. aggregate: Min 1500 KVA

- Purge air control cabinet : The air should have instrument air quality and should not under any circumstances have more than 15 degrees Celsius.

- Strainer Element: MODENTIC SS304 (37-400 micron) DN150 6"
- Flowmeter, Light, Pressure Transmitter, Y-strainer, Pressure Cabinets

- Sound Pressure Level (SPL) (1 m free field) 98